



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Almora
 Phone No.: 05962-2234049, E-mail: eealm.ujs.uk@gmail.com


Test Report ID: 821/UJS/DLWQTM/2024-25


Dated: 05/06/2024

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Country Wide Public School, Tana, Someshwar, Almora		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	SURFACE WATER	SAMPLE DESCRIPTION	ONE WATER SAMPLE SUBMITTED FROM COUNTRY WIDE PUBLIC SCHOOL, TANA, SOMESHWAR ALMORA.
Reference Sample Identification:	DLWQTM/UJS/ALM/821		DATE OF START OF ANALYSIS 03/06/2024
			DATE OF END OF ANALYSIS 05/06/2024
Date and Time of Sample Received: 03/06/2024 11:00AM	Sample Collected by:	Mr. Arjun Singh Bora	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.52	6.5 to 8.5	No Relaxation	IS 3025 Pt-11-2022
2.	Total Dissolved Solids (TDS), mg/L	110	500	2000	IS 3025 Pt-16-2023
3.	Turbidity, NTU	0.58	1	5	IS 3025 Pt-10-2023
4.	Total Alkalinity (as CaCO ₃), mg/L	42	200	600	IS 3025 (Part 23): 2023
5.	Total Hardness (as CaCO ₃), mg/L	44	200	600	IS 3025 (Part 21): 2009
6.	Colour, Hazen	Less than 5	5	15	IS 3025 (Part 4): 2021
7.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2022
8.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 1984
9.	Calcium (as Ca), mg/l	9.6	75	200	IS 3025 (Part 40): 2023
10.	Magnesium (as Mg), mg/l	4.86	30	100	APHA 23 rd -3500-Mg B-2023
11.	Chloride, mg/l	3.96	250	1000	IS 3025 (Part 32), 2019,
12.	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA 23 rd ED-9223-B
13.	E.coli, MPN/100ML	Absent	Absent	Absent	APHA 23 rd ED-9223-B


 (Lab Chemist)
 Chemist
 Pappu Bishr
 Lab U. J. S., Almora


 Authorized Signatory
 (Assistant Engineer)
 Authorized Signatory
 District Water Quality Testing
 Monitoring Laboratory
 Uttarakhand Jal Sansthan, Almora

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of the testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
- Results apply to the sample as received.
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.